





# ESM4C\_25141466

7 - A test log book accompanies this certificate and is up-to-date		(N/A...)
<b>EMERGENCY LUMINAIRES</b>		
5.2.2	8 - Luminaires are suitably spaced in accordance with authenticated spacing or design data <i>illumination is normally checked by visual inspection and from the design spacings.</i> <i>Where illumination is verified by the measurements, insert a 'tick' and provide details of the instruments used and the results on a separate numbered page.</i> <i>For guidance on measurements refer to Annex 2 of BS 5266-1.</i>	(...✓...) (N/A...)
5.2.5 5.2.6.6	9 - Luminaires are installed where necessary to cover balconies, lifts, plant rooms and the like	(...✓...)
5.2.8	10 - Luminaires are sited at or near balconies 2 m or relevant 'points of emphasis' in accordance with BS 5266-1:2016 and in positions/locations identified from the fire safety risk assessment	(...✓...)
6.1	11 - Non-maintained luminaires operate on failure of supply to local lighting circuit	(...✓...)
6.3	12 - Illumination is at least two luminaires provided in each section of the escape route and open areas	(...✓...)
6.4	13 - Luminaires are mounted at least 2 m above the floor and at a suitable height/position to avoid areas of smoke accumulation and/or obstructions	(...✓...)
6.7	14 - Luminaires are suitably protected for their location (IP rating)	(...✓...)
7.4	15 - All luminaires and converted luminaires conform to BS EN 60598-2-22	(...✓...)
12	16 - Luminaires and lamps are in good condition	(...✓...)
	17 - Luminaires have been tested and found to operate for their full rated duration	(...✓...)
	18 - After the system has been tested, each luminaire charging indicator operates correctly	(...✓...)
<b>SAFETY SIGNS</b>		
5.2.5.1	19 - Escape route signs comply with BS EN ISO 7010 and are located and operated in accordance with BS 5499-4	(...✓...)
5.2.5.2	20 - Other safety signs are located and operated in accordance with BS 5499-10	(...✓...)

This certificate is based on the model in Annex 1 of BS 5266 Part 1:2016. Published by Certsure LLP © Copyright Certsure LLP (August 2016)

## EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1:2016 Emergency Lighting - Part 1: Code of practice for the emergency lighting of premises

**PART 5: COMPLIANCE CHECKLIST** - Continued failure a declared outcome is identified by an 'X', the details of the deviation must be accurately recorded on page 3 (PART 6)

✓ indicates that an item (Clause No.) was assessed and the declared outcome was SATISFACTORY. ✓ indicates that a deviation was identified. 'N/A' indicates that the assessment of an item was NOT APPLICABLE to the particular installation

Clause No.	Items assessed for compliance	Declared outcome
<b>TEST FACILITIES</b>		
8.3.3	21 - A sufficient number of suitably located test facilities are provided with their function clearly identified	(...✓...)
	22 - All test facilities are suitable to apply a test for the relevant duration	(...✓...)
	23 - The test facilities act upon the intended luminaires only	(...✓...)
	24 - Test facilities are protected from unauthorised operation	(...✓...)
	25 - Automatic test facilities conform to BS EN 62004	(N/A...)
10.7	26 - Training on the use of the test facilities and recording the results of tests has been given to the responsible person	(N/A...)
<b>WIRING/EQUIPMENT</b>		
8.1	27 - Fixed wiring of the emergency lighting installation has been installed in accordance with BS 7671 (as amended)	(...✓...)
8.3.2	28 - Isolators, switches and protective devices of the emergency system protected/located and appropriately labelled so as to prevent unauthorised use	(...✓...)
<b>FINAL DECLARATION TO BE CONDUCTED AT COMPLETION</b>		
10.7	29 - User has been provided with accurate system documentation (drawings, layout plans)	(N/A...)
	30 - User has been made aware of the action they need to take in the event of a test failure	(N/A...)
	31 - The user has been made aware of the need to maintain an up-to-date test log book	(...✓...)
11	32 - The emergency lighting system operates correctly when tested	(...✓...)
	33 - Deviations (if any) have been recorded accurately	(...✓...)
Assessment carried out by Name (capital): PRAKASHKUMAR PATEL Signature: [Redacted] Position: QS Date: 12/04/2022		
<b>PART 6: DETAILS OF DEVIATIONS FROM THE RECOMMENDATIONS OF BS 5266-1</b>		
Clause No.	Details of the deviation	(See additional page No. N/A...)
N/A		
<b>PART 7: COMMENTS ON EXISTING INSTALLATION</b> (Any defects identified on the existing emergency lighting installation, not covered by this certificate, should be recorded below)		
N/A (See additional page No. N/A...)		

This certificate is based on the model in Annex 1 of BS 5266 Part 1:2016. Published by Certsure LLP © Copyright Certsure LLP (August 2016)

### NOTES FOR RECIPIENT

#### THIS CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

Only the contractor responsible for the small emergency lighting installation work, is authorised to issue this Emergency Lighting Completion Certificate.

This certificate should be read in conjunction and supported by photometric data (see Note 1) and an appropriate Test Log Book, and include the following documents, which should be referenced as PART 4:

- Electrical Installation Certificate (see Note 2), or
- Minor Electrical Installation Works Certificate (see Note 2), and/or
- Emergency Lighting Periodic Inspection and Test Certificate (see Note 3)

Note 1: This can be in any of the following formats (in all cases appropriate de-rating factors must be used, and identified to meet worst case requirements):

- Authenticated spacing data such as ICCL 1001 registered tables;
- Calculations as detailed in BS 5266-1:2016, Annex A, and CIBSE / SLL Guide L612;
- Appropriate computer print-out of results.

Note 2: The electrical safety aspects of the emergency lighting installation must also be certified in accordance with BS 7671: Requirements for Electrical Installations (as amended) by issuing an Electrical Installation Certificate or, where appropriate, a Minor Electrical Installation Works Certificate.

Note 3: Where this certificate relates to an addition or alteration that necessitated the carrying out of a periodic inspection on the existing emergency lighting installation, the 'Emergency Lighting Periodic Inspection and Testing Certificate' should accompany this certificate.

You should have received the certificate, consisting of 3 pages in total, marked 'Original', and the contractor responsible for carrying out the work should have retained the certificate marked 'Duplicate'.

#### Certificate of emergency lighting installation works

This certificate should have been issued on completion of new emergency lighting installation work that includes no more than 25 new self-contained emergency lighting luminaires, where the contractor issuing the certificate is solely responsible for the design, construction and the inspection and testing of the work. The work may be either a new emergency lighting installation or an addition or alteration to an existing emergency lighting installation.

The completed certificate is intended to confirm that the emergency lighting installation detailed in this certificate has been fully inspected and tested and, except for the deviations (if any) recorded in the certificate, complies with the requirements of BS 7671: Requirements for Electrical Installations (as amended) and the relevant recommendations and requirements of the emergency lighting standards listed below:

- BS 5266-1:2016 - Emergency Lighting Part 1: Code of practice for the emergency lighting of premises
- BS EN 1838-2012 - Lighting applications - Emergency lighting
- BS EN 50172:2004 (BS 5266-8:2004) - Emergency escape lighting systems

The certificate should not have been issued for the periodic inspection and testing of an existing emergency lighting installation, for which an Emergency Lighting Periodic Inspection and Testing Certificate should be used.

The completed certificate should have been issued to the Responsible Person for the premises (as identified in PART 3 'Declaration of Conformity') and must be accompanied by all the following documents:

- a completed and signed compliance checklist;
- photometric design data;
- an appropriate test log book.

The contractor should have signed PART 3, attesting ALL required documentation is present, absence of any of above documents (i, ii or iii) renders this certificate invalid.

#### BS 5266-1 defines the 'Responsible Person' as -

'Delegated individual who is responsible for the provision and operation of appropriate emergency escape lighting. Note this might not necessarily be the same as the responsible person as defined in the Regulatory Reform (Fire Safety) Order 2005.'

If you were the person entering the work, but not the user of the installation, you should pass this certificate, or a full copy of it, including these notes and any related reference documents, to the user immediately. This certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the emergency lighting installation in the future. If you later vacate the premises, the certificate will demonstrate to the new Responsible Person that the emergency lighting installation covered by this certificate complied with the Standards listed above and the requirements of BS 7671 (as amended), at the time the certificate was issued.

Emergency lighting systems should be maintained by regular inspections and tests in accordance with Clause 7.2 of BS EN 50172:2004 (BS 5266-8:2004).

25141466 ESM4C

### EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1:2016 'Emergency lighting - Part 1: Code of practice for the emergency lighting of premises'

**PART 1: DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION**

<b>DETAILS OF THE CONTRACTOR</b>	<b>DETAILS OF THE CLIENT</b>	<b>DETAILS OF THE INSTALLATION</b>
Name: [REDACTED]	Reference Number (Ref): N/A	Occupier: PRATHAP SRISKANDARAJAH BLACKBIRD NEWS
Address: [REDACTED]	Name: PRATHAP SRISKANDARAJAH BLACKBIRD NEWS	Address: Blackbird News, 222 Blackbird Road, Leicester, Leicestershire
Postcode: [REDACTED] Tel No: [REDACTED]	Address: Blackbird News, 222 Blackbird Road, Leicester, Leicestershire	Postcode: LE4 6AF Tel No: N/A

**PART 2: DETAILS OF THE EMERGENCY LIGHTING INSTALLATION COVERED BY THIS CERTIFICATE**

Description and extent of the installation covered by this certificate: ONLY COMMUNAL AREA COVERED BY 7 X EMERGENCY LIGHT

The installation is - New (N/A) or An addition (✓) or An alteration (N/A)

**PART 3: DECLARATION OF CONFORMITY**

In consequence of acceptance of the outcomes declared in this certificate, I hereby declare that the emergency lighting system installation, or part thereof, described in this certificate conforms, to the best of my knowledge and belief, to the appropriate recommendations and requirements given in BS 5266-1:2016 'Emergency lighting - Part 1: Code of practice for emergency lighting of premises', BS EN 1838:2013 'Lighting applications - Emergency lighting and BS EN 18272:2004 'Emergency escape lighting systems, as set out in the outcomes declared on the compliance checklist (pages 2 and 3), except for the deviations recorded in PART 5.

To be signed by the Responsible Person (as defined by BS 5266-1, see 'Notes for Recipient' on behalf of the owner/occupier)

Name (capital): [REDACTED] Signature: [REDACTED] Position: OS Date: 12/04/2022

**This certificate is not valid unless accompanied by current versions of the following documentation:** i) Signed compliance checklist (pages 2 and 3) ii) Photometric design data (see Note 1 of 'Notes for Recipient') iii) Test log book

The contractor issuing this certificate MUST sign to verify that i), ii) and iii) above have been supplied with this certificate and that all essential related reference documents have been recorded in PART 4.

Reviewed by: [REDACTED] Signature: [REDACTED] Position: OS Date: 12/04/2022

**PART 4: RELATED REFERENCE DOCUMENTS**

Please state and provide reference number(s) of all appropriate documentation:

N/A	(Ref No: N/A)	N/A	(Ref No: N/A)	N/A	(Ref No: N/A)	(See additional page No. N/A)
N/A	(Ref No: N/A)	N/A	(Ref No: N/A)	N/A	(Ref No: N/A)	

This certificate is based on the model in Annex I of BS 5266-1:2016. Published by Certare LLP © Copyright Certare LLP (August 2018) Warwick House, Houghton Hall Park, Houghton Fenay, Doncaster, DN10 5ZL

Please see the 'Notes for Recipient' Page 2 of 4

Original (for the person issuing the event)

25141466 ESM4C

### EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1:2016 'Emergency lighting - Part 1: Code of practice for the emergency lighting of premises'

**PART 5: COMPLIANCE CHECKLIST** (Where a declared outcome is identified by an 'X', the details of the deviation must be accurately recorded on page 2 (PART 7))

✓ indicates that an item (Clause No.) was assessed and the declaration outcome was SATISFACTORY. ✗ indicates that a deviation was identified. N/A indicates that the assessment of an item was NOT APPLICABLE to the particular installation.

Clause No.	Items assessed for compliance	Declared outcome
<b>SYSTEM DESIGN AND DOCUMENTS</b>		
4.2	1 - Plans are available and correct	(N/A)
4.2.8	2 - Design provides coverage for all areas identified by the fire safety risk assessment	(N/A)
5.2.8	3 - Design provides coverage for all hazards identified by the fire safety risk assessment	(N/A)
6.7	4 - System has the correct mode of operation	(✓)
11	5 - System is designed for the correct emergency duration period	(✓)
	6 - Photometric design data accompanies this certificate	(N/A)
	7 - A test log book accompanies this certificate and is up-to-date	(N/A)
<b>EMERGENCY LUMINAIRES</b>		
5.2.2	8 - Luminaires are suitably spaced in accordance with authenticated spacing or design data. Illumination is normally checked by visual inspection and from the design spacings. Where illumination is verified by site measurements, insert a 'tick' and provide details of the instruments used and the results on a separate numbered page. For guidance on measurements refer to Annex D of BS 5266-1.	(✓)
5.2.8.5 5.2.8.6	9 - Luminaires are installed where necessary to cover toilets, lifts, plant rooms and the like	(✓)
5.2.8	10 - Luminaires are sited at or near (within 2 m) all relevant 'points of emphasis' in accordance with BS 5266-1:2016 and in positions/locations identified from the fire safety risk assessment	(✓)
6.1	11 - Non-maintained luminaires operate on failure of supply to local lighting circuit	(✓)
6.3	12 - Illumination from at least two luminaires provided in each section of the escape route and open areas	(✓)
6.4	13 - Luminaires are mounted at least 2 m above the floor and at a suitable height/position to avoid areas of smoke accumulation and/or obstructions	(✓)
6.7	14 - Luminaires are suitably protected for their location (IP Rating)	(✓)
7.6	15 - All luminaires and connected luminaires conform to BS EN 60598-2-22	(✓)
12	16 - Luminaires and lamps are in good condition	(✓)
	17 - Luminaires have been tested and found to operate for their full rated duration	(✓)
	18 - After the system has been tested, each luminaire charging indicator operates correctly	(✓)
<b>SAFETY SIGNS</b>		
5.2.8.1	19 - Escape route signs comply with BS EN 18272:2004 and are located and operated in accordance with BS 5499-4	(✓)
5.2.8.2	20 - Other safety signs are located and operated in accordance with BS 5499-10	(✓)

This certificate is based on the model in Annex I of BS 5266-1:2016. Published by Certare LLP © Copyright Certare LLP (August 2018) Warwick House, Houghton Hall Park, Houghton Fenay, Doncaster, DN10 5ZL

Page 2 of 4

Original (for the person issuing the event)

25141466 ESM4C

### EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1:2016 'Emergency lighting - Part 1: Code of practice for the emergency lighting of premises'

**PART 5: COMPLIANCE CHECKLIST** (Where a declared outcome is identified by an 'X', the details of the deviation must be accurately recorded on page 2 (PART 7))

✓ indicates that an item (Clause No.) was assessed and the declaration outcome was SATISFACTORY. ✗ indicates that a deviation was identified. N/A indicates that the assessment of an item was NOT APPLICABLE to the particular installation.

Clause No.	Items assessed for compliance	Declared outcome
<b>TEST FACILITIES</b>		
8.3.3	21 - A sufficient number of suitably located test facilities are provided with their function clearly identified	(✓)
	22 - All test facilities are suitable to apply a test for the relevant duration	(✓)
	23 - The test facilities act upon the intended luminaires only	(✓)
	24 - Test facilities are protected from unauthorised operation	(✓)
	25 - Automatic test facilities conform to BS EN 62084	(N/A)
10.7	26 - Training on the use of the test facilities and recording the results of tests has been given to the responsible person	(N/A)
<b>WIRING/EQUIPMENT</b>		
8.1	27 - Fixed wiring of the emergency lighting installation has been installed in accordance with BS 7671 (as amended)	(✓)
8.3.2	28 - Isolators, switches and protective devices of the emergency system protected/located and appropriately labelled so as to prevent unauthorised use	(✓)
<b>FINAL DECLARATION TO BE CONDUCTED AT COMPLETION</b>		
10.7	29 - User has been provided with accurate system documentation (drawings layout plans)	(N/A)

This certificate is based on the model in Annex I of BS 5266-1:2016. Published by Certare LLP © Copyright Certare LLP (August 2018) Warwick House, Houghton Hall Park, Houghton Fenay, Doncaster, DN10 5ZL

Original (for the person issuing the event)

This protected PDF is view-only.





# IPN18C\_25135032



Additional pages? (N/A) State page numbers: (N/A) Improvement recommended for items: (N/A)  
 Immediate action required for items: (N/A) Further investigation required for items: (N/A)  
 Urgent remedial action required for items: (N/A)

The proposed date for the next inspection should take into consideration any legislative or existing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

This report is based on the model form shown in Appendix A of BS 7671.  
 Published by Certsure LLP. Certsure LLP operates the NICEIC & ELECSA brands.  
 Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 2DX. © Copyright Certsure LLP (July 2018)



This report is not valid if the serial number has been defaced or altered

25135032

IPN18C

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

### PART 7: DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018 as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the installation covered by this report: SINGLE PHASE BOARD DUAL RCD WITH 12 BREAKER AND 3 BLANKS (see additional page No. N/A)

Agreed limitations including the reasons, if any, on the inspection and testing: N/A

Extent of sampling: 15% RANDOMLY SAMPLED FROM OVER ALL INSTALLATION (see additional page No. N/A)

Operational limitations including the reasons: N/A (see additional page No. N/A)

### PART 8: SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements	Number and type of live conductors	Nature of supply parameters
TN-C-S (N/A) TN-S (✓) TT (N/A)	AC 1-phase, 2-wire: (✓) 2-phase, 3-wire: (N/A) 3-phase, 3-wire: (N/A)	Normal line voltage, U <sub>n</sub> : (N/A) V Normal line voltage to Earth, U <sub>e</sub> : (N/A) V Normal frequency, f: (N/A) Hz
Other (state): N/A	DC 2-wire: (N/A) 3-wire: (N/A) Other: (N/A)	Prospective fault current, I <sub>pf</sub> : (N/A) kA External loop impedance, Z <sub>e</sub> : (N/A) Ω
Supply protective device (BS EN 13651) Type: II	Confirmation of supply polarity: (✓) Other sources of supply (as detailed on attached schedule) Page No: (N/A)	
Rated current: 100 A		

### PART 9: PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of Earthing	Main protective conductors	Main protective bonding connections	Main switch / Switch fuse / Circuit-breaker / RCD
Distributor's facility: (✓) Installation earth electrode: (N/A)	Earthing conductor: (✓) Material: Copper Size: 16 mm <sup>2</sup>	Water installation pipes: (✓) Gas installation pipes: (✓) Structural steel: (N/A) Oil installation pipes: (N/A) Lightning protection: (N/A) Other (state): N/A	Type: (BS EN 50447-3) Location: (ELECTRICAL CUPBOARD) No. of poles: (3) Current rating: (100) A Rating / setting of device: (100) mA Voltage rating: (230) V
Where an earth electrode is used insert Type - (rod), tap, etc.: None Location: N/A Electrode resistance to Earth: (N/A) Ω	Main protective bonding conductors: (✓) Material: Copper Size: 16 mm <sup>2</sup> Connection / continuity verified: (✓)	Where an RCD is used as the main switch RCD rated residual operating current, I <sub>Δn</sub> : (N/A) mA Measured operating time: (N/A) ms	Rated time delay: (N/A) ms

\*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I<sub>pf</sub>, and external earth fault loop impedance, Z<sub>e</sub>, must be recorded.

All fields must be completed. Enter either, as appropriate: ✓ if Acceptable condition; N/A if Not applicable; LIM if a Limitation exists; or Code appropriately - CODE: CF, CZ, CZ or FF (codes to be recorded in PART 6 with additional comments (where appropriate) on attached numbered sheets)



This report is not valid if the serial number has been defaced or altered

25135032

IPN18C

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

### PART 10: SCHEDULE OF ITEMS INSPECTED

1. External condition of electrical intake equipment (visual inspection only) (if inadequate items are identified with the intake equipment, it is recommended the person ordering the report refers to the appropriate authority)	4. Other methods of protection Details should be provided on separate sheets: Page No: (N/A)	5.24 Single-pole switching or protective devices in live conductors only: (✓)
1.1 Service cable: (✓) 1.2 Service lead: (✓)	5. Distribution equipment	5.25 Protection against mechanical damage where cables enter equipment: (✓)
1.3 Earthing arrangement: (✓) 1.4 Motor talks: (✓)	5.1 Adequacy of working space / accessibility of equipment: (✓)	5.26 Protection against electromagnetic effects where cables enter ferromagnetic enclosures: (N/A)
1.5 Metering equipment: (✓) 1.6 Isolator (where present): (✓)	5.2 Security of fixing: (✓)	6. Distribution / final circuits
2. Presence of adequate arrangements for parallel or switched alternative sources	5.3 Condition of insulation of live parts: (✓)	6.1 Identification of conductors: (✓)
2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (N/A)	5.4 Adequacy / security of barriers: (✓)	6.2 Cables correctly supported throughout their length: (✓)
2.2 Adequate arrangements where generating set operates in parallel with the public supply: (N/A)	5.5 Condition of enclosure(s) in terms of IP rating: (✓)	6.3 Condition of insulation of live parts: (✓)
2.3 Presence of alternative / additional supply arrangement (warning notices) at or near equipment, where required: (N/A)	5.6 Condition of enclosure(s) in terms of fire rating: (✓)	6.4 Non-sheathed cables protected by enclosures in conduit, ducting or trunking: (✓)
3. Automatic disconnection of supply	5.7 Enclosure not damaged / deteriorated so as to impair safety: (✓)	6.5 Suitability of containment systems for continued use (including flexible conduit): (✓)
3.1 Main earthing and bonding arrangements	5.8 Presence and effectiveness of obstacles: (✓)	6.6 Cables correctly terminated in enclosures (include extent of sampling in PART 7 of report): (N/A)
a) Presence and condition of distributor's earthing arrangement: (✓)	5.9 Presence of main switches (where required): (✓)	6.7 Indication of SPD(s) conditioned functionally confirmed: (N/A)
b) Presence and condition of earth electrode arrangement, if present: (N/A)	5.10 Operation of main switches (functional check): (✓)	6.8 Adequacy of AFDD(s), where specified: (N/A)
c) Adequacy of earthing conductor size: (✓)	5.11 Correct identification of circuit protective devices: (✓)	6.9 Confirmation that conductor connections, including conductors to busbars are correctly located in terminals and are tight and secure: (✓)
d) Adequacy of earthing conductor connections: (✓)	5.12 Adequacy of protective devices for prospective fault current: (N/A)	6.10 Examination of cables for signs of unacceptable thermal and mechanical damage / deterioration: (✓)
e) Accessibility of earthing conductor connections: (✓)	5.13 RCD(s) provided for fault protection - includes RCBOs: (N/A)	6.11 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation: (✓)
f) Adequacy of main protective bonding conductor size(s): (✓)	5.14 RCD(s) provided for additional protection - includes RCBOs: (N/A)	6.12 Adequacy of protective devices type and rated current for fault protection: (✓)
g) Adequacy of main protective bonding conductor connection(s): (✓)	5.15 RCD(s) provided for protection against fire - includes RCBOs: (N/A)	6.13 Presence and adequacy of circuit protective conductors: (✓)
h) Accessibility and condition of other protective bonding connections: (✓)	5.16 Manual operation of circuit breakers and RCDs to prove disconnection: (✓)	6.14 Co-ordination between conductors and overhead protective devices: (✓)
i) Provision of earthing / bonding labels at all appropriate locations: (✓)	5.17 Confirmation that integral reset button switch causes RCD(s) to trip when operated (functional check): (✓)	6.15 Cable installation methods / practices appropriate to the type and nature of installation and external influences: (✓)
3.2 FELV	5.18 Presence of RCD six-monthly test notice at or near equipment, where required: (✓)	6.16 Cables where exposed to direct sunlight, of a suitable type or adequately protected against solar radiation: (✓)
a) Source providing at least single separation: (N/A)	5.19 Presence of diagrams, charts or schedules at or near equipment, where required: (✓)	6.17 Cables adequately protected against damage and abrasion: (✓)
b) Plugs, socket outlets and the like not interchangeable with those of other systems within the premises: (N/A)	5.20 Presence of non-standard (mixed) cable colour warning notices at or near equipment, where required: (✓)	
	5.21 Presence of next inspection recommendation label: (✓)	
	5.22 All other required labelling provided: (✓)	
	5.23 Compatibility of protective devices (old, base(s) and other components): (✓)	

All fields must be completed. Enter either, as appropriate: ✓ if Acceptable condition; N/A if Not applicable; LIM if a Limitation exists; or Code appropriately - CODE: CF, CZ, CZ or FF (codes to be recorded in PART 6 with additional comments (where appropriate) on attached numbered sheets)



This report is not valid if the serial number has been defaced or altered

25135032

IPN18C

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

### PART 10: SCHEDULE OF ITEMS INSPECTED

6.16 Provision of additional protection by an RCD not exceeding 30 mA	6.28 Single-pole switching or protective devices in live conductors only: (✓)	8. Current using equipment (appropriately connected)
a) For all socket-outlets with a rated current not exceeding 32 A, unless exempt: (✓)	6.27 Adequacy of connections, including conductors and accessories, and to fixed and stationary equipment: (✓)	8.1 Condition of equipment in terms of IP rating: (✓)
b) Supplies for mobile equipment with a rated current not exceeding 32 A for use outdoors: (✓)	7. Isolation and switching	8.2 Equipment does not constitute a fire hazard: (✓)
c) For cables concealed in walls / partitions at a depth of less than 50 mm: (✓)	7.1 Isolators	8.3 Enclosure not damaged / deteriorated so as to impair safety: (✓)
		8.4 Suitability for the environment and external influences: (✓)
		8.5 Security of fixing: (✓)



Original (to be present on every page)

Original (to be present on every page)

Original (to be present on every page)

