Appendix 1

	Basis of	Anticipated		Individual Project		
Issues to be dealt with	Requirement	Cost	Schemes		Issues/Risks	Comments/notes
		in £'000s		in £'000s		
Regulatory Reform (Fire Safety) Order 2005	Legislative Requirement		Undertake fire risk assessment (FRA) of the structure in all Council buildings as required by the legislation. Phase 1 High Risk buildings -£185k. Phase 2 - Medium and other buildings - £95k (2009/2010)		Breach of legislation Potential for death occupants or other. Substantial damage to assets	Report introduces need/requirements for higher risk works to be undertaken
Fire Risk Reductions - Undertaking high risk items identified in assessment from previous item	Health & Safety	£126	Ashfield School - including sealing fire doors, address fire compartmentation issues. Dunblane Avenue - including sealing fire doors, Sulgrave Road - including infilling holes in walls Herrick Lodge EPH - including extend fire escape lighting, doors to activate with fire alarm, additional signage	£11 £2	Breach of legislation Potential for death occupants or other. Substantial damage to assets	Some high risk (identified via Risk Management) buildings already have FRA completed under a trial. These have been identified here. Note:- this list of sites will become extensive once all surveys are completed.
			10 York Road - including infilling holes in walls	£3		
			Millgate School - including sealing fire doors, infilling holes in walls	£10	1	
		Leicester Leys Leisure Centre - including extend fire escape lighting, sealing fire doors, attend to ramp platforms, infilling holes in walls	£15			
			Beaumont Enterprise Centre - including sealing fire doors, amend compartmentation	£8		

				Individual		
	Basis of	Anticipated		Project		
Issues to be dealt with	Requirement		Schemes		Issues/Risks	Comments/notes
		in £'000s		in £'000s		
			Pilot House - including sealing fire doors, infilling holes in walls, repairs to fire escape guards to open sided stairs	£4		
			Linwood Workshops - including infilling holes in walls, extend door to proper width	£4		
Safe Roof working - Prevention of Unauthorised access	Case Law & Health & Safety		Northfields Primary School		Regular access being made onto roof by children. School has attempted to reduce but failed.	Successful court cases against Portsmouth City Council, Longslade School. Regular damage occuring to
			Fosse Primary		Regular access being made onto roof by children.	buildings. Potential injury to individuals (children/thieves) in event of accident.
			Braunstone Grove Comm Centre		Regular access being made onto roof by children.	Potential for damaged tiles etc to fall and water leaks. Encourages access
			Sulgrave Road	£12	Regular access being made onto roof by children. Lead theft already occurred to new roof. Skylights have been stamped on with workers below but no broken yet.	for theft. Original design often left roofs easy to climb onto. Further sites being identifed.
			Highfields Library		Regular access being made onto roof by children.	
Asbestos remedial Works			Approx 350 buildings have been surveyed and this has identified some £700k of high priority works which need undertaking. These would be prioritised using the agreed algorithm - A three year programme of £41 K pa (single year only allowed here)		there is a risk to members of the public which could result in injury to their health and claims against the Council exemplified in numerous courts cases nationallly	Various court cases with charges against Councils.We are working under legislative requirements, for managing asbestos within our estate. We are undertaking surveys as required which result in us having to remove or manage the risks identified. We have a corporate potlicy - removal as necessary or manage insitu. This means we have an ongoing management need beyond identification and removal of risks. This figure supplements CMF to enable increased removal times and covver a 3 year programme

				Individual		
	Basis of	Anticipated		Project		
Issues to be dealt with	Requirement		Schemes	,	Issues/Risks	Comments/notes
	rtoquironioni	in £'000s		in £'000s		
Safe Access to water hygiene sites to enable			To date 161 sites have been		Inability to test water which may	We are working under legislative
testing		£40	inspected with many others to follow.	£40	lead to exposure to harmful	requirements, for managing water
lesung			Of these it was found to be			hygiene within our estate. As part of our
			impossible to gain access to 10 sites		children, staff and public - there is	,.
			due to access problems. This sum is		a risk to members of the public	undertaking risk assessments as
			to provide access for these and			required which result in work having to
			future surveys.		health and claims against the	be undertaken to ensure contamination
					Council exemplified in some	levels do not exceed strict prescribed
					recent deaths and numerous	legislative guidelines. This also
					courts cases nationally.	includes the setting up of regular
					courts cases nationality.	testing, inspection and monitoring
						regimes requiring an ongoing
						management need. We therefore have
						to provide safe access routes for
						continuous monitoring.
						g-
Works to boundary fencing	Case Law &	£108	Spinney Hill Park - many panels	£0	Fencing in poor condition.	Successful case against Derby City
works to boundary rending	Health & Safety		corroded through the metalwork and	20	Potential for injury. To be dealt	Council involving a fatality of a child
	ricaliti & Galety		stability compromised		with as part of Heritage Lottery	with a falling fence panel. Potential for
					Fund Bid	injury to occur from any boundary walls
			Belgrave Cemetery		From earth mounding on	and fencing which is in a poor state of
			beigrave Cemetery	£3	neighbouring side, children are	repair. Overall inspection will be
					leaping over spiked fence.	undertaken within Property Health
						Surveys - this is picking up sites with a
			Inglehurst School		Structural wall between school	potential to cause harm. The highest
					grounds and alleyway to private	priorities are listed here, but we need to
					housing alley is severly bowing	establish a bigger picture of the issues
					with potential to fall into school	through fuller detailed investigations
			Abbey Pumping Station	£33	Bow topped palisade fence is in a	and the anticiaption is that there will be
					parlous state with bent and	works required to rectify H&S issues .
					split/broken pales. Numerous	The Park Wardens now regularly check
					repairs been previously	fencing in the light of the Derby case.
					completed. Fence allows access	
					to children to site. Pales become	
					bent towards visiting public.	
Site specific Issues						
1						
						•

				Individual		
		Anticipated		Project		
Issues to be dealt with	Requirement	Cost	Schemes	Amount	Issues/Risks	Comments/notes
		in £'000s		in £'000s		
Defective Dosing Equipment	Technical Issue & Health & Safety		Various Swimming Pools (excluding Spence St)			System installed still operates but now obsolete as firm no longer exists. Spares unable to be located. System being 'mackled ' up or undertaken by hand.
Future items not included in this bid						
Obsolete Fire Alarm system	Technical Issue & Health & Safety		Knighton Fields Primary School			System installed still operates but now obsolete as system is not sutiable for present day requirements. There is no monitoring, zoning or automatic detection.
Obsolete Heating pipework system	Technical Issue & Health & Safety		Oaklands Special School		Potenial for leakage and cold zones. Could affect the children's and others' health	New boilers have already been installed, but distribution of pipework is of poor and needs replacement to be work effectively. Redesign required.
Defective Floor drainage and slopes	Case Law & Health & Safety		Sulgrave Road		Potential injury claims (some may come after several years)	Court case against Bristol City Council but one off site. Many staff complaints about working conditions at the site and having to work in damp conditions
Safe Roof working - Prevention of Unauthorised access			Northfields NHC	?	Investigation yet to be undertaken	
			Goldhill Adventure Playground	?	Investigation yet to be undertaken	
			De Montfort Hall		Lead theft following easy access. Listed building leaves lead still vulnerable.	
Totals		£700				