



Our Ref: FP012086  
Your Ref:  
Please ask for: Simon Headley  
Date: 31/01/25

Leicester City Council  
Licensing Authority  
115 Charles Street  
Leicester  
LE1 1FZ

Dear Sir/Madam

**The Regulatory Reform (Fire Safety) Order 2005 (as amended)**

**Premises: Piccadilly Cinema, Green Lane Road, Leicester, Leicestershire, LE5 3TH**

**Application for New Premises Licence Basement Restaurant and Bar at the above address**

The Fire Authority hereby acknowledges receipt of the above applications for registration but has some queries and conditions to add to the licence if approved.

The Authority brings to your attention the Regulatory Reform (Fire Safety) Order 2005 (as amended). Under this order, the responsible person must ensure that a suitable and sufficient Fire Risk Assessment is carried out for the premises/event. This must be completed by a competent person and must be recorded and made available for inspection by the Fire Authority.

Leicestershire Fire and Rescue Service has noted that we have received two applications for a premises licence for the same basement area on the 14/01/2025 and 31/01/2025 for what appears to be the same proposed basement restaurant Machhi Restaurant and Bar and one for Tandel Restaurant and Bar. Both applicants can't be occupying the same premises? Please can you confirm.


The premises has escape in one direction only upstairs to a final fire exit/entrance and therefore the premises is limited to 60 persons in number including staff.



**Privacy Notice**

Leicestershire Fire and Rescue Service regard your privacy as important and comply with the Data Protection Act 2018. The personal information we hold about you will be used in order for us to ensure compliance with the Regulatory Reform (Fire Safety) Order 2005 (as amended). We may also use the information to contact you to ask you about the service we provided, this is for our monitoring purposes. Your personal data is held securely on our system and will not be shared with any other third party unless we have lawful basis to do so. The information will be held for a period of time defined in our retention and disposal schedule. Further information can be obtained from our Data Protection Officer by emailing: [dpo@leics-fire.gov.uk](mailto:dpo@leics-fire.gov.uk) or telephone: 0116 210 5555.

Yours faithfully



Simon Headley  
Fire Protection Inspecting Officer  
For and on behalf of the Chief Fire & Rescue Officer