

**Application for the review of a premises licence or club premises certificate under the
Licensing Act 2003**

PLEASE READ THE FOLLOWING INSTRUCTIONS FIRST

Before completing this form please read the guidance notes at the end of the form.
If you are completing this form by hand please write legibly in block capitals. In all cases ensure that your answers are inside the boxes and written in black ink. Use additional sheets if necessary. You may wish to keep a copy of the completed form for your records.

I Mrs Sophie Smith (Fore Protection Officer at Leicestershire Fire & Rescue
(Insert name of applicant)

apply for the review of a premises licence under section 51 / apply for the review of a club premises certificate under section 87 of the Licensing Act 2003 for the premises described in Part 1 below (delete as applicable)

Part 1 – Premises or club premises details

Postal address of premises or, if none, ordnance survey map reference or description	
Glassy Club Green Lane Road Leicester	
Post town Leicester	Post code (if known) LE5 3TH
Name of premises licence holder or club holding club premises certificate (if known) Pravesh Macan	
Number of premises licence or club premises certificate (if known) LEIPRM1570	

Part 2 - Applicant details

I am

Please tick ✓ yes

1) an individual, body or business which is not a responsible authority (please read guidance note 1, and complete (A) or (B) below)

2) a responsible authority (please complete (C) below) ✓

3) a member of the club to which this application relates (please complete (A) below)

(A) DETAILS OF INDIVIDUAL APPLICANT (fill in as applicable)

Please tick ✓ yes

Mr Mrs Miss Ms Other title
(for example, Rev)

Surname

First names

Please tick ✓ yes

I am 18 years old or over

**Current postal
address if
different from
premises
address**

Post town

Post Code

Daytime contact telephone number

**E-mail address
(optional)**

(B) DETAILS OF OTHER APPLICANT

Name and address


Telephone number (if any)

E-mail address (optional)

(C) DETAILS OF RESPONSIBLE AUTHORITY APPLICANT

Name and address

Leicestershire Fire & Rescue Authority
Geoff Monk Way
Birstall
Leicester
LE4 3BU

This application to review relates to the following licensing objective(s)

Please tick one or more boxes ✓

- 1) the prevention of crime and disorder
- 2) public safety ✓
- 3) the prevention of public nuisance
- 4) the protection of children from harm ✓

Please state the ground(s) for review (please read guidance note 2)

Upon recent inspection of the premises the licence holder appears to be subletting to another person, who is not the license holder. This person is Arvind Madov.

They are failing to maintain their Fire Safety Duties under The Regulatory Reform (Fire Safety) Act 2005 (as amended).

This was apparent during a recent visit by Leicestershire Fire & Rescue where the following was identified:

- Lack of working fire alarm
- Lack of Fire Risk Assessment
- Lack of any management of fire safety
- The emergency lighting could not be demonstrated as working
- An EICR could not be produced
- Increased risk with excessive use of electrical wires and extension leads
- The ceiling had fallen exposing floorboards to the flats above where vulnerable people live (including a very small child)
- In addition to this there was extreme mould in the premises, and this was passing through to the flats above

Our visit resulted in the issuance of an enforcement notice to the leaseholder and a copy issued to the building owner as an interested party.

Please provide as much information as possible to support the application (please read guidance note 3)

In addition to the above 2 of the exits have been blocked off so there is now only one exit in and out of the premises, under our legislation this will restrict the use of the premises to 60 people. The manual call point next to the only exit has been taped over and is now unable to be used.

The license holder Pravesh Macan was not contactable and the person on site Arvind Madov informed that he is a joint leaseholder of the premises. It is not clear if he is a licence holder, i do not believe him to be and i believe the premises to be run by him.

He was unable to provide any requested information or documentation to support elements of fire safety.

The premises was extremely dirty and run down, and all the fire safety measured on site appeared to have failed.

Leicestershire Fire & Rescue inspected the premises in 2024 which resulted in the issuance of a Deficiency Notice. This is our lowest level of enforcement, an informal notice where a follow up visit is not carried out but there is an expectation that works are carried out. During our visit it became apparent that none of the deficiencies in the original notice had been addressed. When questions Arvind Madov was unaware of the original notice that had been addressed to Pravesh Macan.

Our main concern here must be the poor fire separation between the commercial licensed area and the flats above, there is introduced risk in the bar area introduced by the licence holder – or person who is running the place – ie no EICR, excessive use of electrical extension leads, no means of warning and poor management of fire safety.

Please tick ✓ yes

Have you made an application for review relating to the premises before

If yes please state the date of that application

Day	Month	Year
<input type="text"/>	<input type="text"/>	<input type="text"/>

If you have made representations before relating to the premises please state what they were and when you made them

Please tick ✓

yes


- I have sent copies of this form and enclosures to the responsible authorities and the premises licence holder or club holding the club premises certificate, as appropriate
- I understand that if I do not comply with the above requirements my application will be rejected

IT IS AN OFFENCE, UNDER SECTION 158 OF THE LICENSING ACT 2003, TO MAKE A FALSE STATEMENT IN OR IN CONNECTION WITH THIS APPLICATION. THOSE WHO MAKE A FALSE STATEMENT MAY BE LIABLE ON SUMMARY CONVICTION TO A FINE OF ANY AMOUNT.

Part 3 – Signatures (please read guidance note 4)

Signature of applicant or applicant’s solicitor or other duly authorised agent (please read guidance note 5). **If signing on behalf of the applicant please state in what capacity.**

Signature



Date 19.05.2026

Capacity Fire Protection Officer

Contact name (where not previously given) and postal address for correspondence associated with this application (please read guidance note 6)

Post town

Post Code

Telephone number (if any)

If you would prefer us to correspond with you using an e-mail address your e-mail address (optional)

NOTE

Any personal data that you provide will be processed in accordance with current data protection laws. It will be used by Leicester City Council and our partners to deliver and improve services and fulfil our legal duties. We will not disclose any personal information to anyone else unless required or allowed to do so by law. Read more about how we use personal data in our Privacy Notice on our website www.leicester.gov.uk

Notes for Guidance

1. A responsible authority includes the local police, fire and rescue authority and other statutory bodies which exercise specific functions in the local area.
2. The ground(s) for review must be based on one of the licensing objectives.
3. Please list any additional information or details for example dates of problems which are included in the grounds for review if available.
4. The application form must be signed.
5. An applicant's agent (for example solicitor) may sign the form on their behalf provided that they have actual authority to do so.
6. This is the address which we shall use to correspond with you about this application.